



Results Report

Order ID: 1K04897

Karl Environmental Group 20 Lauck Road Mohnton, PA 19540	Project: Sussex County Technical School 105 N. Church Road Sparata, NJ 07871
Attn: Aja Slater	Regulatory ID:

Sample Number: 1K04897-01	Site: ST-Blank	Sample ID: Blank
Collector: AS	Collect Date: 11/23/2021 5:30 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 17:05	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K04897-02	Site: ST-TrainerFill	Sample ID: West Building
Collector: AS	Collect Date: 11/23/2021 4:45 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	5.77	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 17:00	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K04897-03	Site: ST-IM-1FL-TRAINER	Sample ID: West Building
Collector: AS	Collect Date: 11/23/2021 4:45 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 16:58	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K04897-04	Site: ST-DW-1FL-132	Sample ID: West Building
Collector: AS	Collect Date: 11/23/2021 5:12 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.05	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 16:01	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K04897-05	Site: ST-DW-1FL-BOYSGYM	Sample ID: West Building
Collector: AS	Collect Date: 11/23/2021 4:52 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 16:57	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 12/10/2021 4:48 pm 1K04897
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 1K04897-06	Site: ST-DW-1FL-GIRLSGYM	Sample ID: West Building							
Collector: AS	Collect Date: 11/23/2021 4:52 am	Sample Type:							
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead	4.23	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 16:55	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K04897-07	Site: ST-DW-1FL-134	Sample ID: West Building							
Collector: AS	Collect Date: 11/23/2021 4:55 am	Sample Type:							
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead	7.75	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 17:06	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K04897-08	Site: ST-DW-1FL-143	Sample ID: West Building							
Collector: AS	Collect Date: 11/23/2021 4:57 am	Sample Type:							
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead	10.9	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 17:16	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K04897-09	Site: ST-DW-1FL-135	Sample ID: West Building							
Collector: AS	Collect Date: 11/23/2021 4:57 am	Sample Type:							
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead	4.09	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 17:14	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K04897-10	Site: ST-DW-1FL-129	Sample ID: West Building							
Collector: AS	Collect Date: 11/23/2021 5:15 am	Sample Type:							
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead	16.4	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 17:13	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K04897-11	Site: ST-DW-1FL-142	Sample ID: West Building							
Collector: AS	Collect Date: 11/23/2021 5:00 am	Sample Type:							
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead	1.12	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 17:09	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K04897-12	Site: ST-DW-1FL-100HALL-R	Sample ID: West Building							
Collector: AS	Collect Date: 11/23/2021 5:16 am	Sample Type:							
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead	3.63	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 17:08	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 12/10/2021 4:48 pm 1K04897
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 1K04897-13	Site: ST-DW-1FL-100HALL-L	Sample ID: West Building
Collector: AS	Collect Date: 11/23/2021 5:16 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.63	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 17:28	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K04897-14	Site: ST-DW-2FL-205HALL-R	Sample ID: West Building
Collector: AS	Collect Date: 11/23/2021 5:18 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.89	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 17:27	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K04897-15	Site: ST-DW-2FL-205HALL-L	Sample ID: West Building
Collector: AS	Collect Date: 11/23/2021 5:18 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.99	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 17:11	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K04897-16	Site: ST-TL-1FL-126-L	Sample ID: West Building
Collector: AS	Collect Date: 11/23/2021 5:20 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 17:24	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K04897-17	Site: ST-TL-1FL-126-R	Sample ID: West Building
Collector: AS	Collect Date: 11/23/2021 5:20 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 17:19	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K04897-18	Site: ST-WC-1FL-141	Sample ID: West Building
Collector: AS	Collect Date: 11/23/2021 5:07 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.03	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 17:17	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K04897-19	Site: ST-FP-1FL-125-R	Sample ID: West Building
Collector: AS	Collect Date: 11/23/2021 5:30 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	7.24	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 16:09	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 12/10/2021 4:48 pm 1K04897
 STL_Results Revision #1.9 Effective: 04/16/2020

SUBURBAN TESTING LABS



1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com

PA DEP # 06-00208
 NJDEP# PA081



SUBURBAN TESTING LABS

Sample Number: 1K04897-20	Site: ST-KC-1FL-125	Sample ID: West Building
Collector: AS	Collect Date: 11/23/2021 5:30 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	5.45	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 17:25	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K04897-21	Site: ST-IM-1FL-124	Sample ID: West Building
Collector: AS	Collect Date: 11/23/2021 5:35 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 16:12	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K04897-22	Site: ST-KC-1FL-124-1	Sample ID: West Building
Collector: AS	Collect Date: 11/23/2021 5:40 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.04	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 18:15	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K04897-23	Site: ST-FP-1FL-108	Sample ID: West Building
Collector: AS	Collect Date: 11/23/2021 5:21 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.13	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 18:28	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K04897-24	Site: ST-KC-1FL-108	Sample ID: West Building
Collector: AS	Collect Date: 11/23/2021 5:21 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/29/21	MKR	12/09/21 13:55	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K04897-25	Site: ST-KC-1FL-124-2	Sample ID: West Building
Collector: AS	Collect Date: 11/23/2021 5:35 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.79	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 18:31	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K04897-26	Site: ST-FP-1FL-124-2	Sample ID: West Building
Collector: AS	Collect Date: 11/23/2021 5:40 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	7.27	µg/L	EPA 200.8	1.00	1	11/24/21	JED	12/04/21 18:32	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 12/10/2021 4:48 pm 1K04897
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 1K04897-27 Site: ST-FP-1FL-124-1 Sample ID: West Building
 Collector: AS Collect Date: 11/23/2021 5:40 am Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/24/21 JED 12/04/21 18:05 MKR

Sample Number: 1K04897-28 Site: ST-KC-1FL-124-3 Sample ID: West Building
 Collector: AS Collect Date: 11/23/2021 5:35 am Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/24/21 JED 12/04/21 18:20 MKR

Sample Number: 1K04897-29 Site: ST-FP-1FL-124-3 Sample ID: West Building
 Collector: AS Collect Date: 11/23/2021 5:35 am Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/24/21 JED 12/04/21 18:23 MKR

Sample Number: 1K04897-30 Site: ST-KC-1FL-124-5 Sample ID: West Building
 Collector: AS Collect Date: 11/23/2021 5:35 am Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/24/21 JED 12/04/21 18:24 MKR

Sample Number: 1K04897-31 Site: ST-WC-1FL-109 Sample ID: West Building
 Collector: AS Collect Date: 11/23/2021 5:56 am Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/24/21 JED 12/04/21 18:26 MKR

Sample Number: 1K04897-32 Site: ST-KC-1FL-124-6 Sample ID: West Building
 Collector: AS Collect Date: 11/23/2021 5:35 am Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 3.83 µg/L EPA 200.8 1.00 1 11/24/21 JED 12/04/21 18:34 MKR

Sample Number: 1K04897-33 Site: ST-BF-1FL-109 Sample ID: West Building
 Collector: AS Collect Date: 11/23/2021 5:56 am Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/24/21 JED 12/04/21 18:07 MKR

Report Generated On: 12/10/2021 4:48 pm 1K04897
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 1K04897-34 Site: ST-KC-1FL-124-4 Sample ID: West Building
 Collector: AS Collect Date: 11/23/2021 5:35 am Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 1.36 µg/L EPA 200.8 1.00 1 11/24/21 JED 12/04/21 18:21 MKR

Sample Number: 1K04897-35 Site: ST-DW-1FL-HALL123-L Sample ID: West Building
 Collector: AS Collect Date: 11/23/2021 5:50 am Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 13.2 µg/L EPA 200.8 1.00 1 11/24/21 JED 12/04/21 18:10 MKR

Sample Number: 1K04897-36 Site: ST-DW-1FL-HALL123-C Sample ID: West Building
 Collector: AS Collect Date: 11/23/2021 5:50 am Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 3.48 µg/L EPA 200.8 1.00 1 11/24/21 JED 12/04/21 18:12 MKR

Sample Number: 1K04897-37 Site: ST-DW-1FL-HALL123-R Sample ID: West Building
 Collector: AS Collect Date: 11/23/2021 5:50 am Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 4.36 µg/L EPA 200.8 1.00 1 11/24/21 JED 12/04/21 18:13 MKR

Sample Number: 1K04897-38 Site: ST-DW-2FL-HALL219-L Sample ID: West Building
 Collector: AS Collect Date: 11/23/2021 5:53 am Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 7.04 µg/L EPA 200.8 1.00 1 11/24/21 JED 12/04/21 16:17 MKR

Sample Number: 1K04897-39 Site: ST-DW-2FL-HALL219-R Sample ID: West Building
 Collector: AS Collect Date: 11/23/2021 5:53 am Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 8.86 µg/L EPA 200.8 1.00 1 11/24/21 JED 12/04/21 18:08 MKR

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Report Generated On: 12/10/2021 4:48 pm 1K04897
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Ryan F Knerr
Project Manager II

Report Generated On: 12/10/2021 4:48 pm 1K04897
STL_Results Revision #1.9 Effective: 04/16/2020





1K04897
Ryan F Kneer

TAT(Check One): Standard 24hr 48hr 72hr Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)
Order ID: _____

Client Name: Karl Environmental Group
Address: 20 Lauck Road
Mohnton, PA 19540
Contact Name: Aja Slater
Phone: 610-856-7100
Fax: 610-856-5040
Email: aslater@karlenv.com

Project Name: Sussex County Technical School- Lead in Drinking Water
Address: West Building
105 N. Church Road, Sparta, NJ 07871
Payment / P.O. Info: 21-0906

Comments: NJ DOE Lead in Drinking Water Samples - First Draw - PG 1 of 6

SVTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below			Comments / Field Data:
							Matrix	Sample Type	Bottle Type	
	ST-BLANK	11/23/21	0530	AS	Lead 200.8 NJ DOE	1	PW G	P	H	Blank
	ST-PP-1FL-SHOWER	11/23/21		AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-Trainer Fall	11/23/21	0445	AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-IM-1FL-TRAINER	11/23/21	0445	AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-DW-1FL-132	11/23/21	0512	AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-DW-1FL-BOYSGYM	11/23/21	0452	AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-DW-1FL-GIRLSGYM	11/23/21	0452	AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-DW-1FL-134	11/23/21	0455	AS	Lead 200.8 NJ DOE	1	PW G	P	H	

Relinquished By: <u>AS</u> Received By: <u>MAJ</u>	Date: <u>11-23-21</u> Time: <u>0916</u>	Temp °C: _____ Acceptable: Y / N	Sample Conditions: Submitted with COC? <u>Y / N</u> Number of containers match number on COC? <u>Y / N</u> All containers in tact? <u>Y / N</u> Tests within holding times? <u>Y / N</u> 40 mL VOA vials free of headspace? <u>Y / N</u>	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	SDWA Sample Types D=Distribution E=Entry Point R=Raw C=Check S=Special M=Maximum Residence	Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	Bottle Type Key P = Plastic G = Glass O = Other	Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email <input type="checkbox"/> Other <input type="checkbox"/> Return a copy of this form with Report
---	--	-------------------------------------	---	--	--	---	--	--	--

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.



1K04897
Ryan F Knerr

TAT (Check One): Standard 24hr 48hr 72hr Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Karl Environmental Group

Address: 20 Lauck Road

Mohnton, PA 19540

Contact Name: Aja Slater

Phone: 610-856-7700

Fax: 610-856-5040

Email: aslater@karlenv.com

Project Name: Sussex County Technical School- Lead in Drinking Water

Address: West Building

105 N. Church Road, Sparta, NJ 07871

Payment / P.O. Info: 21-0906

Comments:

NJ DOE Lead in Drinking Water Samples - First Draw - PG 2 of 6

SVTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below			Comments / Field Data:
							Matrix	Sample Type	Bottle Type	
	ST-DW-1FL-143	11/23/21	0457	AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-DW-1FL-135	11/23/21	0457	AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-NS-1FL-129	11/23/21	0515	AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-WC-1FL-142	11/23/21	0500	AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-DW-1FL-100HALL-R *	11/23/21	0516	AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-DW-1FL-100HALL-L	11/23/21	0516	AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-DW-2FL-205HALL-R	11/23/21	0518	AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-DW-2FL-205HALL-L	11/23/21	0518	AS	Lead 200.8 NJ DOE	1	PW G	P	H	

Relinquished By: <u>AS</u> Date: <u>11/23/21</u> Time: <u>0916</u>	Sample Conditions: Submitted with COC? <u>Y/N</u> Number of containers match number on COC? <u>Y/N</u> All containers in tact? <u>Y/N</u> Tests within holding times? <u>Y/N</u> 40 mL VOA vials free of headspace? <u>Y/N</u>	Matrix Key: NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Reporting Options: <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email <input type="checkbox"/> Other <input type="checkbox"/> Return a copy of this form with Report
Relinquished By: _____ Date: _____ Time: _____	Temp °C: _____ Acceptable: Y / N	SDWA Sample Types: D=Distribution E=Entry Point R=Raw C=Check S=Special M=Maximum Residence	Bottle Type Key: P = Plastic G = Glass O = Other Preservative Key: N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required
Relinquished By: <u>AS</u> Date: <u>11/23/21</u> Time: <u>916</u>	Temp °C: <u>12.35</u> Acceptable: <u>Y/N</u>	Sample Type Key: G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	

Signing this form indicates your agreement with SVTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014

Shaded areas are for SVTL use only.



1K04897
Ryan F. Knerr

Client Name: Karl Environmental Group
Address: 20 Lauck Road
Mohnton, PA 19540
Contact Name: Aja Slater

Phone: 610-856-7700
Fax: 610-856-5040
Email: aslater@karlenv.com

Project Name: Sussex County Technical School- Lead in Drinking Water
Address: West Building
105 N. Church Road, Sparta, NJ 07871
Payment / P.O. Info: 21-0906

TAT (Check One): Standard 24hr 48hr 72hr Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Comments: NJ DOE Lead in Drinking Water Samples - First Draw - PG 3 of 6

SWTL Sample Number	Sample Description / Site ID	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested	Bottle Quantity	See Codes Below				Comments / Field Data
							Matrix	Sample Type	Bottle Type	Preservative	
	Lead 200.8 NJ DOE	11/23/21	AS	AS	Lead 200.8 NJ DOE	1	PW-G	P	H	H	
	ST-TL-1FL-126-L	11/23/21	0520	AS	Lead 200.8 NJ DOE	1	PW-G	P	H	H	
	ST-TL-1FL-126-R	11/23/21	0520	AS	Lead 200.8 NJ DOE	1	PW-G	P	H	H	
	ST-WC-1FL-141	11/23/21	0507	AS	Lead 200.8 NJ DOE	1	PW-G	P	H	H	
	ST-FP-1FL-125-R	11/23/21	0530	AS	Lead 200.8 NJ DOE	1	PW-G	P	H	H	
	ST-FP-1FL-125-L	11/23/21		AS	Lead 200.8 NJ DOE	1	PW-G	P	H	H	
	ST-KC-1FL-125	11/23/21	0530	AS	Lead 200.8 NJ DOE	1	PW-G	P	H	H	
	ST-IM-1FL-124	11/23/21	0535	AS	Lead 200.8 NJ DOE	1	PW-G	P	H	H	

Relinquished By: <u>AS</u>	Date: <u>11/23/21</u>	Sample Conditions: Submitted with COC? <u>Y/N</u>	Matrix Key: NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key: P = Plastic G = Glass O = Other	Reporting Options: <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email <input type="checkbox"/> Other
Received By: _____	Date: _____ Time: <u>0916</u>	Number of containers match number on COC? <u>Y/N</u>	Sample Type Key: G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	Preservative Key: N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	<input type="checkbox"/> Return a copy of this form with Report
Relinquished By: _____	Date: _____ Time: _____	All containers in tact? <u>Y/N</u>	SDWA Sample Types: D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence		
Received in Lab By: <u>MRWD</u>	Date: <u>11/23/21</u> Time: <u>0916</u>	Tests within holding times? <u>Y/N</u>			
	Date: _____ Time: _____	40 mL VOA vials free of headspace? <u>Y/N</u>			

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014

* Does not exist



TAT (Check One): Standard 24hr 48hr 72hr Other
 (Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

1K04897
Ryan F. Knerr

Client Name: Karl Environmental Group
 Address: 20 Lauck Road
Mohnton, PA 19540
 Contact Name: Aja Slater

Phone: 610-856-5040
 Fax: 610-856-5040
 Email: aslater@karlenv.com

Project Name: Sussex County Technical School- Lead in Drinking Water
 Address: West Building
105 N. Church Road, Sparta, NJ 07871
 Payment / P.O. Info: 21-0906

Comments: NJ DOE Lead in Drinking Water Samples - First Draw - PG 4 of 6

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	See Codes Below				Comments / Field Data:
						Bottle Quantity	Matrix	Sample Type	Bottle Type	
	ST-KC-1FL-124-1	11/23/21	0540	AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-CF-1FL-108	11/23/21		AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-SO-1FL-108	11/23/21		AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-FP-1FL-108	11/23/21	0521	AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-KC-1FL-108	11/23/21	0521	AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-IL-1FL-106	11/23/21		AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-KC-1FL-124-2	11/23/21	0535	AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-FP-1FL-124-2	11/23/21	0540	AS	Lead 200.8 NJ DOE	1	PW G	P	H	

Relinquished By: <u>(Signature)</u>	Date: <u>11-23-21</u>	Sample Conditions	Matrix Key	Bottle Type Key	Reporting Options
Received By: <u>(Signature)</u>	Time: <u>0916</u>	Submitted with COC? <u>(Y/N)</u>	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)	P = Plastic G = Glass O = Other	<input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email <input type="checkbox"/> Other
Relinquished By:	Date:	Number of containers match number on COC? <u>(Y/N)</u>	PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₂ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	<input type="checkbox"/> Return a copy of this form with Report
Received in Lab By: <u>(Signature)</u>	Time: <u>1916</u>	All containers in tact? <u>(Y/N)</u>	Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	SDWA Sample Types D=Distribution E=Entry Point R=Raw C=Check S=Special M=Maximum Residence	
	Date:	Tests within holding times? <u>(Y/N)</u>			
	Time:	40 mL VOA vials free of headspace? <u>(Y/N)</u>			
	Date:	Temp °C: _____			
	Time:	Acceptable: Y / N			
	Date:	Temp °C: _____			
	Time:	Acceptable: Y / N			
	Date:	Temp °C: <u>12.3°C</u>			
	Time:	Acceptable: <u>(Y/N)</u>			

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
 Shaded areas are for SWTL use only.



1K04897
Ryan F. Kneer



Client Name: Karl Environmental Gr
Address: 20 Lauck Road
Mohnton, PA 19540
Contact Name: Aja Slater

Phone: 610-856-7700
Fax: 610-856-5040
Email: aslater@karlenv.com

TAT (Check One) Standard 24hr 48hr 72hr Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply.)
Order ID: _____

Project Name: Sussex County Technical School- Lead in Drinking Water
Address: West Building
105 N. Church Road, Sparta, NJ 07871
Payment / P.O. Info: 21-0906

Comments: NJ DOE Lead in Drinking Water Samples - First Draw - PG 5 of 6

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below			Comments / Field Data:
							Matrix	Sample Type	Bottle Type	
	ST-FP-1FL-124-1	11/23/21	0540	AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-KC-1FL-124-3*	11/23/21	0535	AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-FP-1FL-124-3	11/23/21	0535	AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-KC-1FL-124-5	11/23/21	0535	AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-WC-1FL-109	11/23/21	0556	AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-KC-1FL-124-6	11/23/21	0535	AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-BF-1FL-109	11/23/21	0556	AS	Lead 200.8 NJ DOE	1	PW G	P	H	
	ST-KC-1FL-124-4*	11/23/21	0535	AS	Lead 200.8 NJ DOE	1	PW G	P	H	

Relinquished By: <u>JA-8</u>	Date: <u>11/23/21</u>	Temp °C: _____	Acceptable: Y / N
Received By: _____	Time: <u>0916</u>	Temp °C: _____	Acceptable: Y / N
Relinquished By: _____	Date: _____	Temp °C: _____	Acceptable: Y / N
Received in Lab By: <u>ASL 8</u>	Date: <u>11/23/21</u>	Temp °C: <u>12.3°C</u>	Acceptable: <u>Y/N</u>
	Time: <u>916</u>		

Sample Conditions	Matrix Key	Bottle Type Key	Reporting Options
Submitted with CCC? <u>Y/N</u>	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	P = Plastic G = Glass O = Other	<input type="checkbox"/> SDWA Reporting PWSID: _____
Number of containers match number on CCC? <u>Y/N</u>		Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	<input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email <input type="checkbox"/> Other
All containers in tact? <u>Y/N</u>	Sample Type Key G = Grab 8HC = 8 Hr. 24HC = 24 Hr. Composite	SDWA Sample Types D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence	<input type="checkbox"/> Return a copy of this form with Report
Tests within holding times <u>Y/N</u>			
40 mL VOA vials free of headspace? <u>Y/N</u>			

Signing this form indicates your agreement with SWTL'S Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.



1K04897
Ryan F Kner

Client Name: Karl Environmental Group
 Address: 20 Lauck Road
Mohnton, PA 19540
 Contact Name: Aja Slater

Phone: 610-856-7700
 Fax: 610-856-5040
 Email: aslater@karlenv.com

Sample Name: Sussex County Technical School- Lead in Drinking Water
 Address: West Building
105 N. Church Road, Sparta, NJ 07871
 Payment / P.O. Info: 21-0906

TAT (Check One) Standard 24hr 48hr 72hr Other
 (Additional charges may apply for rush TAT. If not specified, standard TAT will apply.)
 Order ID: _____

Comments: NJ DOE Lead in Drinking Water Samples - First Draw - PG 6 of 6

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	See Codes Below			Comments / Field Data:	
						Bottle Quantity	Matrix	Sample Type		
	<u>ST-DW-1FL-HALL123-L</u>	<u>11/23/21</u>	<u>0550</u>	<u>AS</u>	<u>Lead 200.8 NJ DOE</u>	<u>1</u>	<u>PW</u>	<u>G</u>	<u>H</u>	
	<u>ST-DW-1FL-HALL123-C</u>	<u>11/23/21</u>	<u>0550</u>	<u>AS</u>	<u>Lead 200.8 NJ DOE</u>	<u>1</u>	<u>PW</u>	<u>G</u>	<u>H</u>	
	<u>ST-DW-1FL-HALL123-R</u>	<u>11/23/21</u>	<u>0550</u>	<u>AS</u>	<u>Lead 200.8 NJ DOE</u>	<u>1</u>	<u>PW</u>	<u>G</u>	<u>H</u>	
	<u>ST-DW-2FL-HALL219-L</u>	<u>11/23/21</u>	<u>0553</u>	<u>AS</u>	<u>Lead 200.8 NJ DOE</u>	<u>1</u>	<u>PW</u>	<u>G</u>	<u>H</u>	
	<u>ST-DW-2FL-HALL219-R</u>	<u>11/23/21</u>	<u>0553</u>	<u>AS</u>	<u>Lead 200.8 NJ DOE</u>	<u>1</u>	<u>PW</u>	<u>G</u>	<u>H</u>	
	<u>(39) 250 mL P. H₂O₃</u>	<u>11/23/21</u>		<u>AS</u>	<u>Lead 200.8 NJ DOE</u>	<u>1</u>	<u>PW</u>	<u>G</u>	<u>H</u>	
	<u>P# L2. 11/23/21 MRW</u>	<u>11/23/21</u>		<u>AS</u>	<u>Lead 200.8 NJ DOE</u>	<u>1</u>	<u>PW</u>	<u>G</u>	<u>H</u>	
		<u>11/23/21</u>		<u>AS</u>	<u>Lead 200.8 NJ DOE</u>	<u>1</u>	<u>PW</u>	<u>G</u>	<u>H</u>	

Relinquished By: <u>AS</u>	Date: <u>11/23/21</u>	Temp °C: _____	Acceptable: Y / N	Sample Conditions: Submitted with COC? <u>Y</u> / <u>N</u>	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, sol., etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key P = Plastic G = Glass O = Other	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email <input type="checkbox"/> Other <input type="checkbox"/> Return a copy of this form with Report
Received By: _____	Time: <u>0916</u>	Temp °C: _____	Acceptable: Y / N	Number of containers match number on COC? <u>Y</u> / <u>N</u>	Sample Type Key G = Grab 8HC = 8 Hr Composite 24HC = 24 Hr Composite	Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	
Relinquished By: _____	Date: _____	Temp °C: _____	Acceptable: Y / N	All containers in tact? <u>Y</u> / <u>N</u>	SDWA Sample Types D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence		
Received in Lab By: <u>MRW</u>	Date: <u>11/23/21</u>	Temp °C: <u>12.3</u>	Acceptable: <u>Y</u> / <u>N</u>	Tests within holding times <u>Y</u> / <u>N</u>			
	Time: <u>0916</u>			40 mL VOA vials free of headspace? <u>Y</u> / <u>N</u>			

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
 Shaded areas are for SWTL use only.